Energy performance certificate (EPC)					
28 The Grange MORETON-IN-MARSH GL56 0AU	Energy rating	Valid until: 4 April 2033			
		Certificate number: 0850-3025-5204-8817-7204			
Property type	Semi-detached house				
Total floor area		66 square metres			

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read <u>guidance for landlords on the regulations and exemptions</u> (<u>https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance</u>).

Energy efficiency rating for this property

This property's current energy rating is D. It has the potential to be B.

<u>See how to improve this property's energy</u> performance.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Roof	Roof room(s), insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Electric storage heaters	Average
Main heating control	Manual charge control	Poor
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 489 kilowatt hours per square metre (kWh/m2).

Environmental impact of this property This property's potential 2.7 tonnes of CO2 production This property's current environmental impact rating is E. It has the potential to be D. You could improve this property's CO2 emissions by making the suggested changes. Properties get a rating from A (best) to G (worst) This will help to protect the environment. on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment. Environmental impact ratings are based on assumptions about average occupancy and An average household 6 tonnes of CO2 energy use. They may not reflect how energy is produces consumed by the people living at the property. This property produces 5.4 tonnes of CO2

Improve this property's energy rating

Step	Typical installation cost	Typical yearly saving
1. Floor insulation (solid floor)	£4,000 - £6,000	£205
2. High heat retention storage heaters	£1,200 - £1,800	£317
3. Solar water heating	£4,000 - £6,000	£125
4. Solar photovoltaic panels	£3,500 - £5,500	£711

Paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

Estimated yearly energy cost for this property	£1833
Potential saving if you complete every step in order	£646

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used	
Space heating	8395 kWh per year	
Water heating	1784 kWh per year	
Potential energy insulation	savings by installing	
Type of insulation	Amount of energy saved	
Loft insulation	39 kWh per year	
Soving onergy in this property		

Saving energy in this property

Find ways to save energy in your home by visiting <u>www.gov.uk/improve-energy-efficiency</u>.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	
Telephone	
Email	

Accreditation scheme contact details

Accreditation scheme Assessor ID Telephone Email

Assessment details

Assessor's declaration Date of assessment Date of certificate Type of assessment James Goodman 07985496105 <u>idlovetolivehereltd@gmail.com</u>

Elmhurst Energy Systems Ltd EES/004518 01455 883 250 <u>enquiries@elmhurstenergy.co.uk</u>

No related party 5 April 2023 5 April 2023 RdSAP